



AquaMark AM-80V

The “tubes” above are the suction (from city water supply) and discharge lines (supplying water to the building) and are labeled as such. The solid black line is the bypass loop.

When the ball valves on the suction and discharge lines are open and the ball valve on the bypass loop is closed the system is in its normal mode of operation.

When the ball valves on the suction and discharge lines are closed and the ball valve on the bypass loop is open the system can be serviced and water will still be provided to the building at the pressure(s) delivered from the city.

©AQUA MARK